



PFOA Contamination Southern New Hampshire PFC Sampling Results

Updated May 9, 2016

PFOA Sampling Results for Merrimack Village District Water Works

Well Name:	MVD-2	MVD-3	MVD-4 (offline)	MVD-5	MVD-7	MVD-8
4/21/16	Results Pending	Results Pending	Results Pending	Results Pending	Results Pending	Results Pending
4/14/16	Results Pending	Results Pending	Results Pending	Results Pending	Results Pending	Results Pending
4/7/16	28	Not Available – Scheduled Maintenance	94	52	28	8.6
3/31/16	27	Not Available – Scheduled Maintenance	90	56	26	8.5 (9.7 duplicate)
3/9/16	17	Not Available – Scheduled Maintenance	90	54 (52 duplicate)	Not Available – Scheduled Maintenance	Not Available – Scheduled Maintenance

PFOA Sampling Results for Pennichuck Water Works Water Systems – Samples Collected by Pennichuck Water Works

	Bedford Water Corp	Cabot Preserve	English Woods	Souhegan Woods	Harvest Village	Ministerial DEP	Pennichuck Litchfield Water System	Pennichuck Water Treatment Plant	Harris Pond	Merrimack River	Powder Hill
Town:	Bedford	Bedford	Bedford	Amherst	Londonderry	Londonderry	Litchfield	Nashua			Bedford
Source Water Desc.:	Wells	Water from MVD	Wells	Wells	Wells	Wells	Wells	Surface Water	Pennichuck Raw Water	Pennichuck Raw Water	Manchester Water Works
Pop. Served:	165	940	50	290	175	160	3600	87500			1472
5/3/16	Not Sampled	Results Pending	Not Sampled	Results Pending	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled
4/26/16	Not Sampled	38	Not Sampled	2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled
4/20/16	Not Sampled	Results Pending	Not Sampled	Results Pending	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled
4/13/16	8.1	Results Pending	3	Results Pending	Not Sampled	4	Results Pending	Results Pending	Not Sampled	Not Sampled	Not Sampled
4/6/16	Not Sampled	52	Not Sampled	4.9	6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled

3/16/16	Not Sampled	36	Not Sampled	3	Not Sampled	Not Sampled	7/9	3	9	2.1	Not Sampled
---------	-------------	----	-------------	---	-------------	-------------	-----	---	---	-----	-------------