



The
NEW HAMPSHIRE DEPARTMENT OF ENVIRONMENTAL SERVICES

hereby issues

LARGE GROUNDWATER WITHDRAWAL PERMIT

NO. LGWP-2004-0004

to the permittee

PENACOOK-BOSCAWEN WATER PRECINCT (PBWP)
9 WOODBURY LANE
BOSCAWEN, NH 03303
(603) 332-4096

for the withdrawal of the following volumes of groundwater from well:

PBWP #3 – 288,000 gallons over any 24-hour period


located at the Merrimack County Farm site in Boscawen, NH (Tax Map 49, Lot 16)

Date of Issuance: November 3, 2004
Date of Expiration: November 3, 2014

Pursuant to authority in N.H. RSA 485-C:21, the New Hampshire Department of Environmental Services (Department), hereby grants this permit to withdraw groundwater from well PBWP #3, subject to the following conditions:

1. Application of Env-Ws 388 - The permittee shall continue to comply with the requirements of Env-Ws 388 at all times.
2. Inspections - Pursuant to RSA 485-C:15, the permittee shall allow any authorized member of the Department's staff, or its agent, to enter the property covered by this permit for the purpose of collecting information, examining records, collecting water level measurements, or undertaking other action associated with this permit.
3. Water Conservation - Pursuant to RSA 485:61, PBWP shall implement a water accounting, water audit and leak detection program in accordance with "Manual of Water Supply Practices, Water Audits Leak Detection" document identification number AWWA M36, American Water Works Association, 1999. PBWP shall repair all identified leaks within 60 days unless it is demonstrated it is not feasible due to the location or size of the leak, and, if unaccounted for water exceeds 15%, a response plan to reduce unaccounted for water to less than 15% shall be submitted to the Department within 60 days. PBWP shall confirm that this work will be completed and provide a schedule to implement the water conservation requirements.
4. Mitigation Requirements - In the event that adverse impacts occur, the permittee shall comply with the requirements of Env-Ws 388:19.
5. Registered Water User - The permittee shall become a Registered Water User and maintain the water use reporting requirements of Env-Wr 700 at all times.
6. Permit Renewal - The permittee shall apply for renewal of this permit at least 90 days prior to its expiration date. The permittee shall continue to comply with all conditions in this permit until the permit is renewed or the facility is closed in accordance with all applicable requirements, regardless of whether a renewal application is filed.

Any person aggrieved by any terms or conditions of this permit may appeal in accordance with RSA 541 within 30 days.



Harry T. Stewart, P.E.,
Director Water Division